

Meeting Date:

Sponsor(s):

City of Chicago

Office of the City Clerk Document Tracking Sheet

SO2022-1752

5/25/2022

Hadden (49) Tabares (23) Ervin (28) Taylor (20) Osterman (48) King (4) Sadlowski Garza (10) Rodriguez (22) Harris (8) Mitts (37) Lee (11) Quinn (13) Coleman (16) Cardona, Jr. (31) La Spata (1) Lopez (15) Martin (47) Sigcho-Lopez (25) Napolitano (41) Sawyer (6) Villegas (36) Ramirez-Rosa (35) Curtis (18) Ordinance

Amendment of Municipal Code Section 14X-8-802.2.2 by modifying heating requirements for dwelling and sleeping units

Committee on Zoning, Landmarks and Building Standards

Type:

Title:

Committee(s) Assignment:

SUBSTITUTE ORDINANCE

BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF CHICAGO:

SECTION 1. Section 14X-8-802 of the Municipal Code of Chicago is hereby amended by deleting the language struck through and by inserting the language underscored, as follows:

14X-8-802 HEATING SYSTEMS.

(Omitted text is not affected by this ordinance.)

14X-8-802.2.2 Heat to be provided.

Dwelling units and *sleeping units* to which heat is furnished from a heating plant used in common for the purpose of heating more than one such unit must be supplied with heat from September 15th of each year to June 1st of the succeeding year so that the occupants may secure, without such undue restriction of ventilation as to interfere with proper sanitary conditions when all windows and exterior doors are closed, a minimum temperature of 68°F (20°C) at 8:30 a.m. and thereafter until 10:30 p.m. and 66°F (19°C) at 10:30 p.m. and thereafter until 8:30 a.m. in all habitable spaces, toilet rooms, and bathrooms. *habitable spaces, toilet rooms, and bathrooms.* This section does not prevent an *owner* from disengaging heating equipment or engaging cooling equipment between these dates as long as the required minimum temperature is maintained within *dwelling units* and *sleeping units*.

Exception: In buildings where the same facilities are used to provide both heating and cooling to the units, the minimum temperature is 64°F (18°C) at all hours:

- 1. Between September 15 and October 15, prior to the first date when the nighttime outdoor temperature falls below 45°F (7°C).
- 2. Between May 1 and June 1, on or after the first date when the daytime outdoor temperature exceeds 75°F (24°C).

(Omitted text is not affected by this ordinance.)

14X-8-802.3.2 Heat to be provided.

Indoor occupiable work spaces must be supplied with heat from September 15th of each year to June 1st of the succeeding year so that the workers may secure, without such undue restriction of ventilation as to interfere with proper sanitary conditions when all windows and exterior doors are closed, a minimum temperature of 68°F (20°C) during the period the space is occupied in all *habitable spaces*, *toilet rooms*, and *bathrooms*. This section does not prevent an *owner* from disengaging heating equipment or engaging cooling equipment between these dates as long as the required minimum temperature is maintained.

Exceptions:

1. Where a lower temperature is necessary or expedient for the work or manufacturing process of such business and the moisture content of the air is controlled to maintain a minimum wet bulb temperature of 54°F (12°C).

2. Where a lower temperature is necessary or expedient for the work or manufacturing process of such business, subject to conditions *approved* by the *building official* to reasonably protect the health of the *occupants*.

i

- 3. In buildings where the same facilities are used to provide both heating and cooling, the minimum temperature is 64°F (18°C) at all hours:
 - <u>3.1 Between September 15 and October 15, prior to the first date when the nighttime outdoor temperature falls below 45°F (7°C).</u>
 - <u>3.2 Between May 1 and June 1, on or after the first date when the daytime</u> outdoor temperature exceeds 75°F (24°C).

(Omitted text is not affected by this ordinance.)

SECTION 2. This ordinance shall be in full force and effect following passage and approval.