

The permit holder agrees to hold the City of Chicago harmless for any damage, relocation or replacement costs associated with damage, relocation or removal of private property caused by the City performing work in the public way.

Carlos Ramirez-Rosa 35ⁱⁿ Ward

Page 1

Authority herein given and granted for a period of five (5) years from and after Date of Passage.

Page 3 of 6)

Front-Lit Channel Letters w/ LED Illumination • Raceway Mounted

village:

White Tmcap/ White Return

Proposed Square Footage of this sign:
[Lineal feet of store front
Actual Square Footage AHTwed by

Specifications: LED Channel Letters

- 1 Existing Facade Concrete Block/ Brick
- 2 0 040 Aluminum letter returns painted to match white
- 3 0 125 x 1 white Jewelite tmcap A 040 White Aluminum backing

(interior of sign can will be white for maximum illumination)

- 5 Interone UL approved LED s
- 6 UL approved flexible conduit connectors
- 7 1/8 Acryhte #2283
- 8 UL approved LED transformer (Mean well)
- 9 UL approved waterproof disconnect switch per NEC 600 6
- 10 Aluminum Raceway to match fascia color
- 11 1/4 x2 x11 Aluminum Bracket
- 12 UL approved Liquid tight metallic conduit

(All penetration will be caulked w/ high grade silicone)

- 13 Mounting hardware to suit (Non Corrosive)

Approved Arlon Vinyl

Electrical Detail: Channel Letters

- Mean well CLG 60 12
- (1) 60w Transformers @ 0 80
- Total Amps 0 80 (1) Minimum of 20 amp 120V Circuit Req

General Notes:

This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code

- 1) Grounded and bonded per NEC 600 7/NEC 250
- 2) Existing branch circuit in compliance with NEC 600 5 not to exceed 20 amps
- 3) Sign is to be UL listed per NEC 600 3
- 4) UL disconnect switch per NEC 600 6 required per sign component before leaving manufacturer*

For multiple signs a disconnect is permitted but not required for each section
Va Drain holes at bottom\ of letter cans (2) per letter

Section (5) LED Channel Letter

Raceway mount installation Scale NTS

X

ELECTRICAL NOTES / Sign Company DOES NOT provide primary electrical to sign. Power, to the sign must be done by a licensed electrical contractor or licensed electrician. Each sign must have: 1. A minimum of one dedicated 120V 20A circuit
2. Junction box installed within 6' of sign
3. Three wires: Line, Ground, Neutral

Client	Metro PC	Landlord	Start Date 00/00/0000	Last Revision 00/00/0000	Job# 00000	Drawing* 00000a v1	Client Approval	Landlord Approval	Sales Rep Seung Park	Designer Vernon James
--------	----------	----------	-----------------------	--------------------------	------------	--------------------	-----------------	-------------------	----------------------	-----------------------

Address 3627 W Lawrence Address

Tel Tel

Email Email

COPYRIGHT 2013 BY TFA SIGNS THIS RENDERING IS THE PROPERTY OF TFA SIGNS INC AND THE PARTY WHICH REQUESTED THE RENDERING IT IS AN UNPUBLISHED ORIGINAL DRAWING NOT TO BE REPRODUCED OR EXHIBITED WITHOUT THE CONSENT OF TFA SIGNS INC