

associated with damage, relocation or removal of private property caused by the City performing work in the public way.

2 of 2)

le 2 of 2)
.36

**36" CWS W/VALVE AND CAPPED FOR FUTURE CONNECTION ENGINEERED BY BMCD CWR W/VALVE
AND CAPPED FOR FUTURE CONNECTION ENGINEERED BY BMCD
16" 175# STEAM 8" PUMPED CONDENSATE 3" COMPRESSED AIR 2" TRAPPED CONDENSATE
ENGINEERED BY SUPERIOR**

CONTINUED FROM SHEET 8 OF 9

SCALE IN FEET

PROPOSED CHILLED WATER RETURN PROPOSED CHILLED WATER SERVICE PROPOSED NETWORK SERVICES
INFORMATION TECHNOLOGY FIBER OPTIC CONDUIT PROPOSED STEAM 40 PROPOSED CONDENSED AIR PROPOSED
DRIP

**UNIVERSITY OF CHICAGO WEST PLANT - B113 DISTRIBUTION PIPING
PUBLIC WAY PERMITTING**